

Certificate

No. c5979a-20

Customer:

METZ CONNECT GmbH
Im Tal 2
78176 Blumberg, Germany

Category 6

Test sample(s):

Connecting hardware:

E-DAT C6 2 Port Cat.6

Part no.: (AP) 130738000x-I ; (UP) 130738100x-I ;
(UPk) 130738110x-I ; (UP0) 1307381200-I

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

IEC 60603-7-5 Ed.2.0 (2010-04)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Connecting hardware, Copper, Category 6

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R5979a-20** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after the first issue.

Bexbach, 14. May 2020



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**