

PREMIUM Certificate

no. c60471-20

Customer:

METZ CONNECT GmbH
Ottilienweg 9
78176 Blumberg, Germany

VALID TO MAY 2026

Category 7A

Test sample(s):

Balanced cable:

MC GC1300 pro22 Cat.7A S/FTP LSHF-FR

Part-no.:

308427B34142 (simplex, 1000m); 1308427B34172 (simplex,1000m);
1308427B34141 (simplex 500m); 1308427B34171 (simplex 500m);
308427B34145 (simplex 100m); 1308427B34175 (simplex 100m);
1308427B3414M (simplex); 1308427B3417M (simplex);
1308427B34143 (duplex 500m); 1308427B34173 (duplex 500m);
1308427B34144 (duplex); 1308427B34174 (duplex)

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)
DIN EN 50173-1 (2018-10)
IEC 61156-5 Ed.3.0 (2020-04)

Result(s):

The sample meets the limits of the applied standards and regulations with respect to the parameters indicated above.

Balanced cable, copper, Category 7A

GHMT PREMIUM Verification Program, GHMT PVP

Ongoing compliance with the specifications is monitored within the framework of regular sampling, which cannot be influenced by the customer, thus defining high standards as regards continuous manufacturing quality.

This Certificate refers to the comprehensive test report no. **R60471-20** and shall only be applicable in conjunction with the test report.

Bexbach, 10.12.2025



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 320
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**