

Certificate

No. c8722a-24

Customer:

METZ CONNECT GmbH
Im Tal 2
78176 Blumberg, Germany

Test sample(s):

Connecting hardware:
E-DAT C6 24 Port LSA Cat.6 Patchpanel

Part no.: 130856-E; 130855-E;
130862-11-E; 130862-21-E;
860018-11-E; 130857-E

Category 6

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)
DIN EN 50173-1 (2018-10)
ANSI/TIA-568.2-D (2018-09)
IEC 60603-7-5 Ed.2.0 (2010-04)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Connecting hardware, Copper, Category 6

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R8722a-24** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 01.07.2024



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



*Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.*

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**